

Pressure Distribution, Orifice, Pipe & Pump Sizing

This design worksheet was developed by Saskatchewan Onsite Wastewater Management Association.

The completed installation is to comply with Saskatchewan Onsite Wastewater Disposal Guide 2018

This worksheet is for use in Saskatchewan to: size the orifices in distribution lateral pipes, size effluent delivery piping, and to calculate the required capacity and pressure head capability of the effluent pump.

It can be used for: calculating delivery of effluent to laterals in disposal fields, mounds and sand filters.

**This worksheet does NOT consider all of the mandatory requirements of the Guideline
It is intended for use by persons having training in the private sewage discipline.**

Use only Imperial units of measurement throughout (feet, inches, Imperial gallons, etc...).

Step 1) Select the pressure head to be maintained at the orifices:

Minimum pressure at the orifice:

3/16" or less orifice = 5 ft. Minimum - 13.4.13.3

Annex 8

Design pressure at lateral orifices

ft.

P1

Note: worksheet will not provide an adequate design if laterals are at different elevations. Differing elevations will result in a different pressure head and volume of discharge at the orifices in each lateral. Additional considerations must be made for laterals at differing elevations.

Step 2) Select the size of orifice in the laterals:

Minimum size: 13.4.13.3

1/8"

Orifice Diameter
selected

in.

P2

Annex 8

Note: larger sizes are less likely to plug.

Step. 3) Select the spacing of orifices and determine the number of orifices to be installed in distribution laterals:

Length of Distribution Lateral
From system design drawings

Spacing of Orifices selected for
design

Resulting number of orifices
per lateral

ft.

÷

ft.

=

P3a

Select a spacing of orifices to attain even distribution over the treatment area:

13.4.13.

13.4.13.2

X

=

P3b

From P3a

Number of Laterals

Total Number of Orifices All Laterals

If laterals are of differing lengths, calculate each separately and add the number of orifices together.

Step 4) Determine the minimum pipe size of the distribution laterals:

Enter the system design information into the 3 boxes below. If distribution laterals are of differing lengths, each lateral must be considered separately.

Orifice Diameter <input style="width: 100%;" type="text"/>	Length of Distribution Lateral <input style="width: 100%;" type="text"/>	Total Orifices Each Lateral <input style="width: 100%;" type="text"/>
--	--	---

From P2

From System Design Drawings

From P3a

Use Table A.1.A. (pp 118 - 121) when applying the information entered in this step to determine the minimum size of the distribution lateral pipe.

Size of Distribution Lateral Pipe
From Table 13-12 or 13-13 in. **P4**

Step 5) Determine the total flow from all orifices:

Total Number of Orifices in all laterals <input style="width: 100%;" type="text"/>	X	Gal/min for each Orifice at Head Pressure Selected <input style="width: 100%;" type="text"/>	Imp. gal /min.	=	Total flow from all lateral orifices <input style="width: 100%;" type="text"/>	Imp. gal /min.	P5
--	----------	--	----------------	----------	--	----------------	-----------

From P3b

Table 13-14 and 13-15

Step 6) Select the type and size of effluent delivery pipe:

Use Tables 13-8 and 13-9 to aid in decision. A larger pipe will reduce pressure loss.

Type of pipe used for effluent delivery line	Pipe size selected	inch - NPS
<input style="width: 100%;" type="text"/>	<input style="width: 100%;" type="text"/>	P6

Choose a friction loss from Tables 13-8 and 13-9 in between the bolded lines to ensure a flow velocity between 2 to 5 feet per second. The pipe size selected will affect the amount of friction loss the pump must overcome to deliver effluent.

Step 7) Calculate the equivalent length of pipe for pressure loss due to fittings:

Values from Tables 13-10 or 13-11

Insert total from Worksheet "A" on last page (p.5) of this Pressure Distribution Worksheet

Equivalent Length of All Fittings <input style="width: 100%;" type="text"/>	ft.
For Pressure Loss	

P7

Step 8) Calculate the equivalent length of pipe from pump to the farthest end of header of distribution laterals for pressure loss:

Length of Piping (ft)		Equivalent Length of Fittings (ft)		Length of Pipe for Friction Loss (ft)	
<div style="border: 1px solid black; width: 100%; height: 40px;"></div>	+	<div style="border: 1px solid black; width: 100%; height: 40px;"></div>	=	<div style="border: 1px solid black; width: 100%; height: 40px;"></div>	P8
Length from pump to farthest end of distribution header supplying laterals.		Equivalent fitting length from P7 .		Used to determine total pressure head loss due to friction loss in piping.	

Step 9) Calculate the pressure head loss in delivery pipe including fittings:

Total Length of Pipe for Friction Loss		Friction Loss per 100 feet of pipe		Delivery Piping Pressure Head Loss	
<div style="border: 1px solid black; width: 100%; height: 40px; display: flex; justify-content: center; align-items: center;">Divide by 100 ft.</div>	X	<div style="border: 1px solid black; width: 100%; height: 40px;"></div> ft.	=	<div style="border: 1px solid black; width: 100%; height: 40px;"></div> ft.	P9
From P8		Use Tables 13-8 or 13-9 using flow volume from P5 .			
Don't forget to divide the length by 100 feet to match the factors in the tables.					

Step 10) Calculate the total pressure head required at pump:

Delivery piping pressure loss	<div style="border: 1px solid black; width: 100%; height: 25px;"></div>	ft.	From P9	
	+			
Lift distance of effluent from effluent level in tank to orifices	<div style="border: 1px solid black; width: 100%; height: 25px;"></div>	ft.		Measure from lowest effluent level in tank to elevation of orifices.
	+			
Design pressure at orifices	<div style="border: 1px solid black; width: 100%; height: 25px;"></div>	ft.	From P1	
	+			
Head loss allowed if an inline filter is used in pressure piping	<div style="border: 1px solid black; width: 100%; height: 25px;"></div>	ft.		Explain Pressure Loss Allowed if Applied <div style="border: 1px solid black; width: 100%; height: 25px;"></div>
	+			
Add 1 ft to allow for pressure loss along the distribution lateral	<div style="border: 1px solid black; width: 100%; height: 25px; display: flex; justify-content: center; align-items: center;">1</div>	ft.		
	=			
Total minimum pressure head pump must provide at Imp. gal/min required to supply orifices	<div style="border: 1px solid black; width: 100%; height: 40px;"></div>	ft.	P10	

Step 11) Select the size of the drain back orifice if used and determine the flow from the drain back orifice. Then calculate total flow requirement for pump:

<p>Size of Drain Back Orifice</p> <div style="border: 1px solid black; width: 100px; height: 30px; margin: 5px auto;"></div> <p style="text-align: center;">in.</p>	<p>Determine flow using Head Pressure at Drain Back Orifice</p> <div style="border: 1px solid black; width: 100px; height: 30px; margin: 5px auto;"></div> <p style="text-align: center;">Imp. gal /min</p> <p style="color: red; font-size: small;">Use pressure head from P10 to find flow from Extended Orifice Discharge Table HO109-04</p>	+	<p>Flow from all lateral orifices</p> <div style="border: 1px solid black; width: 100px; height: 30px; margin: 5px auto;"></div> <p style="text-align: center;">Imp. gal /min</p> <p style="color: red; font-size: small;">From P5</p>	=	<p>Total Imp. Gallons per Minute from the pump</p> <div style="border: 1px solid black; width: 150px; height: 30px; margin: 5px auto;"></div> <p style="text-align: center;">Imp. gal /min</p> <p style="color: red; font-size: small;">P11</p>
---	---	---	--	---	---

Step 12) Details of the pump specifications required:

<p>Required Flow Rate (Imp. gal/min)</p> <div style="border: 1px solid black; width: 180px; height: 35px; margin: 5px auto;"></div> <p style="color: red; font-weight: bold; text-align: center;">From P11</p>	@	<p>Required Pressure Head (ft)</p> <div style="border: 1px solid black; width: 180px; height: 35px; margin: 5px auto;"></div> <p style="color: red; font-weight: bold; text-align: center;">From P10</p>
<p>Imp. gal (P11) multiplied by 1.2 = U.S. gallons</p>		<p>Required Flow Rate (US gal/min)</p> <div style="border: 1px solid black; width: 180px; height: 35px; margin: 5px auto;"></div>

Select the appropriate pump by reviewing the pump curve of available pumps. Select a pump that exceeds the requirements set out in this step by approximately 10% considering both pressure head and volume.

Step 13) Consider the pumping demands of the system. If they are considered excessive, redesign the pressure distribution system and recalculate the pump demands.

Worksheet "Appendix A" Determine Equivalent Length of Pipe due to fittings in piping system.

Determine the equivalent length of pipe to allow for friction loss due to fittings in the piping system:

	Number of Fittings		Friction loss as per Tables 131-10 or 13- 11		Total
90° Elbows		X		=	
					+
45° Elbows		X		=	
					+
Gate and Ball Valves		X		=	
					+
Tee-on- Branch (TOB)		X		=	
					+
Tee-on-Runs (TOR)		X		=	
					+
Male Iron pipe Adaptors (MIP) (M/F Threaded Adaptors)		X		=	
					=
Total Equivalent Length of pipe to allow for fittings in piping system					
					(Enter this total, Box P7)